

**Generator Replacement  
Project No. 21-MA-01  
Pre-Bid Meeting**

**June 15, 2021  
10:00 AM**

Attendees:

Kevin Finn, County Connection  
Steve Muhlestein, County Connection  
Patricia Rogers, County Connection  
Mark Beltran, Ray's Electric  
Larry Hicks, G.D. Nielson Construction Inc.  
Jen Kooyman, Coastal Mountain Electric  
Randy Day, Day's Generator Service  
Mo DeLeon, Edward W. Scott Electric Co.  
Eric Goodbar, Amp Electric  
Jaime Ochoa, Amp Electric

Kevin Finn, Contracts and Grants Manager for County Connection, called the meeting to order at 10:00 AM.

All questions and approved equal requests are to be sent to Kevin Finn at [finn@cccta.org](mailto:finn@cccta.org). Answers will be posted on County Connection's website at countyconnection.com. Procurement information is under "About Us" at bottom of main page.

The meeting was moved to where the generator is located at the Administration Building.

The current generator was installed in the 1980s. It provides emergency power for the Administration and Paratransit Buildings. This Bid is for a generator that will provide full power for both buildings.

We need power to be run between the Administration and Paratransit Buildings.

The Bid needs to include the cost of removing the old generator. Removing the old generator off County Connection's property is the responsibility of the Contractor.

The transfer switch is located inside the Electrical Room located inside the Administration Building. (The meeting attendees viewed the inside of the Electrical Room.)

The attendees then looked inside the Electrical Room in the Paratransit Building.

Conduit is going to have to be ran between the Administration and Paratransit Buildings. The meeting attendees were shown the space between the Administration and Paratransit Buildings from the lower level of the buildings and the upper level of the buildings.

QUESTIONS AND ANSWERS:

Q: Does the generator need to be purchased by the Contractor?

A: Yes.

Q: Can conduit be run on the roof of the Administration Building?

A: No.

Q: Is it possible to run conduit between the 1<sup>st</sup> and 2<sup>nd</sup> floors of the Administration Building in the crawl space?

A: Yes, however, the Contractor will have to ask for blueprints before bidding due to conduit, electrical lines, etc. in the crawl space.

Q: Are you particular about the brand of generator?

A: Cummins, Caterpillar or approved equal is fine.

Q: The timeline doesn't give very much time to order the generator and do the installation. Is there some flexibility in the timeline?

A: The timeline is flexible due to COVID restrictions.

Please note: It is the responsibility of prospective Bidders to check County Connection's website for addendums, updates, minutes of meetings, changes, etc.